

EVALUATION

Rooms for physically challenged guests. Form supplied from www.disabledtravel.co.za


Room wheelchair friendly. 2010-09-14

Room wheelchair friendly. 2010-09-14	
Width of floor transfer space for a wheelchair next to toil	et: 1900 x 900 mm
Measurement (length of toilet) Wall to front of toilet pant	: 690 mm
Height of toilet seat:	380 mm
Height of grab rails: Cistern button on top Wall	800 mm
Measurement from wall to centre line of toilet.	490 mm
(Closest wall to the side of the toilet)	
Roll-in shower	
Height of adjustable shower head in shower (lowest point	t) 1340 mm
Height of shower seat	adjustable
Height of shower tap	880 mm
Height of shower grab rail – lowest points	adjustable
Distance from seat to grab rail – is it within reach?	
Tap within reach from seat? - Mobile seat	
Width of shower entrance	980 mm
Height of the leg space underneath the basin	
Floor to bottom of counter top	730 mm
Underside of bowl - midway.	870 mm
Height of top edge of basin	890 - 1890
Height of mirror - from basin to bottom of mirror.	870 mm
Height of Shelf/ Table – built in basin	900 mm
Lever taps?	
Adequate bathroom space for turning chair.	4780 x 1560 mm
Clear width of entrance door to bathroom, measure at the most narrow spot 990 mm	
Main bedroom:	4820 x 4320 mm
Width of floor transfer space for a wheelchair next to bed	160 mm
(Carpets will be taken out, if requested.)	
Open space at the foot of the bed.	2740 mm
Clear width of entrance door to bedroom.	1200 mm
Height of the bed	660 mm
Height of leg space underneath table or desk in room	700 mm
Bedroom Cupboards within reach?	Yes
Lowered hanging rail in cupboard?	1640 mm
Dining room No steps to t	the dining room.
Level access to lounge and outside seating area/braai.	
Derking area and surrounding property powing	

Parking area and surrounding property – paving. Ramp at entrance of establishment? Levelle

Ramp at entrance of establishment?Levelled entrance through parking.Parking bay for disabled available?Yes, next to the room.Valet service for disabled?How can we help you?Access to garden and Swimming poolGarden yes, pool partly.













Link to press http://accessiblesouthafrica.co.za/the-way-things-should-always-be-robertson

Reitzstreet 45, Robertson 6705, South Africa • Tel. / Fax +27 (0)23 626 6218 • Cell 076 1800644 E-mail: info@gubas-dehoek.com • Net: www.gubas-dehoek.com